


CERTIFICATE OF CONFORMITY



BUREAU
VERITAS

Equipment : UPS

Brand Name : 

Test Model No. : SMT1500IC, SMT1000RMI2UC

Multiple Listing : SMT1000ICXXXXXXXX, SMT1500ICXXXXXXXX,
SMT1000RMI2UCXXXXXXXX, SMT1500RMI2UCXXXXXXXX,
SMC1000ICXXXXXXXX, SMC1500ICXXXXXXXX,
SMC1000I-2UCXXXXXXXX, SMC1500I-2UCXXXXXXXX
(X=0-9,A-Z, a-z, "-" or blank)

Applicant : SCHNEIDER ELECTRIC IT CORPORATION,
FKA APC AMERICAN POWER

Test Report No. : CE170613D01



We, **Bureau Veritas Consumer Products Services (H.K.) Ltd., Taoyuan Branch**, declare that the equipment above has been tested in our facility and found compliance with the requirement limits of applicable standards, in accordance with the Directive 2014/30/EU. The test record, data evaluation and Equipment Under Test (EUT) configurations represented herein are true and accurate under the standards herein specified.

EN 62040-2:2006, Category C2

IEC 62040-2:2005 ED 2.0 + Cor.1: 2011

IEC 61000-3-2:2014 ED.4.0, Class A

IEC 61000-4-2:2008 ED.2.0

IEC 61000-4-3:2010 ED.3.2


IEC 61000-4-4:2012 ED.3.0

IEC 61000-4-5:2014 ED.3.0

IEC 61000-4-6:2013 ED.4.0

IEC 61000-4-8:2009 ED.2.0

IEC 61000-2-2:2002 ED.2.0


Kenny Meng / Assistant Manager
Jul. 5, 2017



No. 47-2, 14th Ling, Chia Pau Vil., Lin Kou Dist., New Taipei City, Taiwan (R.O.C.)

Tel: 886-2-26052180 Fax: 886-2-26051924

<http://www.bureauveritas-adt.com> E-Mail: service.adt@tw.bureauveritas.com