

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnectors

Name and address of the applicant

Schneider Electric Industries SAS
35 rue Joseph Monier
92500 Rueil-Malmaison
France

Name and address of the manufacturer

Schneider Electric Industries SAS
31 Rue Pierre Mendès France, Eybens
38050 GRENOBLE Cedex 9
France

Name and address of the factory

Note: When more than one factory, please report on page 2

Schneider Electric A.S.
Cizovska 447
39701 Pisek
Czech Republic

Ratings and principal characteristics

Rated operation voltage (Ue): 690 V
Rated impulse withstand voltage (Uimp): 8 kV
Rated insulation voltage (Ui): 690 V
Conventional free air thermal current (Ith):
V3: 63 A; V4: 80 A

Trademark / Brand (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

V3, V4
to be used with rotary handle:
KCF2PZ, KAF2PZ, KDF2PZ, KBF2PZ
For Add-on modules see Page 2

Additional information (if necessary may also be reported on page 2)

See additional page(s) for further Additional information.
Available accessories:
VBF3, VBF4, VCF3, VCF4, VCCF3, VCCF4, VVE3, VVE4, VVD3,
VVD4

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2020
IEC 60947-1:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

HU23VAR3 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2023-08-21

Signature:


Schmidt Ferencné

Additional information :

Add-on modules:

VZ3/VZ4: main pole module
VZ12: neutral pole module
VZ15: earthing module without contact (PE)
VZ7/VZ20: aux. contact blocks (1NO + 1NC / 2 NO)

Accessories: Vxy

Explanation of type codes:

x: Without: switch body only
CF: main and emergency stop switch disconnecter
for door mounting with 4 screws
CCF: main and emergency stop switch disconnecter
for back of enclosure mounting with 4 screws
BF: main switch disconnecter for door mounting with 4 screws
VE: main and emergency switch disconnecter
VD: main switch disconnecter
y: current rating (3 or 4)



Date: 2023-08-21

Signature:


Schmidt Ferencné